# Overhead Crane Inspection Requirements per OSHA 1910

- **One-time inspection**
  - Initial Inspection, 1910.179(j)(1)(i)
    - Prior to seller turnover to buyer
    - Must be written and on file

- **Regular inspections**
  - Periodic inspections, 1910.179(j)(3)
    - Inspection intervals are useage dependant, 1 to 12 month intervals
      - Must be written and on file
      - Inspection by qualified person
  - Frequent inspections, 1910.179Q)(2)
    - Inspecton intervals are usage dependant, Daily to Monthly
      - Documentation not required
      - Inspection by qualified person
  - Functional test inspections, ASME B30.2-2.1.3
    - Prior to each shift of use
      - Records should be made
      - Inspection by qualified person

- **Hook & Rope/Chain inspections**
  - Hook, 1910.179(j)(2)(iii)
    - Monthly
    - Written with inspectors signiture
    - Inspection by qualified person
  - Wire Rope, 1910.179(m)
    - Monthly
    - Written with inspectors signiture
    - Inspection by qualified person
  - Load Chain, 1910.179(j)(2)(iv)
    - Monthly
    - Written with inspectors signiture
    - Inspection by qualified person

- **Special cases**
  - Substantially modified cranes, ASME B30.2-1.4.3
    - Load Test, as determined by qualified person, ASME B30.2-2.3.2
  - Standby cranes, 1910.179(j)(4)(iii)
    - At least semi-annually
  - Crane not in regular use, 1910.179(j)(4)
    - Less than 6 months
      - Use "Frequent" inspection criteria
    - Greater than 6 months
      - Use "Periodic" inspection criteria